

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 23/06/25

It is certified that an inspection team headed by PHC PILKHUWA

(Name of Officers with designation) from PHC PILKHUWA PHED

inspected the K.D. International School, Khera, Pilkhuwa

(Name & Address of the school) on 23/06/25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. UPJN/HPH/531 dated 21/06/25

of UP Jal Nigam, Hapur (PHED Lab) certified that

the K.D. International School (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 23/06/28

Signature with Seal : Priyanka

Name : DR PRIYANKA

Designation : MSc स्वास्थ्य अधिकारी
प्राथमिक स्वास्थ्य केन्द्र
पिलखुवा, हापुड

Name & Address of the Office / Department :

To

K.D. International School

NH-9, Near Shree petrol pump

Khera, Pilkhuwa, Hapur (U.P.)



District Level Water Analysis Laboratory Uttar Pradesh Jal Nigam , Rural , Hapur (205101) Test Report



TC-12418

Test Report No.	UPJN/HPU/531	Issue Date	TC-12418
ULR NO.	TC1241824000000049F	Location of Testing	
Customer's Name	K.D.INTERNATIONAL SCHOOL KHERA,PILKHUWA, HAPUR		Laboratory
Address	K.D.INTERNATIONAL SCHOOL KHERA,PILKHUWA, HAPUR		
Sampling Method : ISO 17614 (Part -1):2021		Sample Description – Drinking Water	
Basic Details of Sample			
Quantity of Sample	1 Lit.	Sample ID	HPU/21/25/531
Condition of Sample	Plastic Bottle (at Room Temp)	Location of Sampling	K.D.INTERNATIONAL SCHOOL
District	HAPUR	Block	HAPUR
Gram Panchayat		Village	PILKHUWA
Sampling Date	20/06/2025	Sampling Done By	Rahul Kumar
Analysis Start Date	21/06/2025	Analysis Completion Date	21/06/2025


Technical Data of Analysis

S. No.	Test parameters	Unit of Measurement	Observed Value	Specific requirements as per IS 10500		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	pH at 25°C	-	7.60	6.5-8.5	6.5-8.5	IS 3025 (Part II): 2022
2	Turbidity	NTU	2.01	1	5	IS 3025 (Part 10): 2023
3	Total Dissolved Solids	mg/L	87	500	2000	IS 3025 (Part 16): 2023
4	Electrical Conductivity (uS/cm)	mg/L	175	<2500	No relaxation	Standard Value as per WHO (2023)
5	Chloride (as Cl)	mg/L	21	250	1000	IS 3025 (Part 32): 2019
6	Total alkalinity (as CaCO ₃)	mg/L	72	200	600	IS 3025 (Part 23): 2023
7	Total hardness (as CaCO ₃)	mg/L	128	200	600	IS 3025 (Part 21): 2019
8	Calcium (as Ca)	mg/L	76	75	200	IS 3025 (Part 40): 2023
9	Magnesium (as Mg)	mg/L	12	30	100	IS 3025 (Part 46): 2023

Note

1. This Test Report only to the particular sample(s) submitted for Analysis.
2. This Test Report shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this Test Report are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 15 days (in case of non-perishable items only) from the date of issue of tests reports unless otherwise specified.


Reviewed by
(MukeshKumar)


Authorized Signatory
Technical Manager
District Level Water Analysis Laboratory
Hapur UPJN
Page 1 of 1

End of Test Report